

# SAMPLE SITE PLAN – Fireworks Stand

Each application must be accompanied by a fully dimensioned site plan, drawn to scale, showing the exact location of the proposed fireworks stand. The plan must include all structures and improvements located within 35 feet of the fireworks stand. When preparing this plan, all stands must be erected a minimum of 100 feet from any gasoline service station. Failure to submit required site plan that meet these standards shall be grounds for denial of the application.

